

ADDENDUM NO. 1

FOR

**Site Concrete Repairs for:
Greenwood Townhouses
Monroe Housing Commission**

JAMES S. JACOBS ARCHITECTS, PLLC
25 WASHINGTON STREET
MONROE, MICHIGAN 48161
Phone 734-241-7933 Fax 734-241-1181 jimj@jsjacobsarch.com

DATE: August 16, 2019
PROJECT NO.: 201924
PAGE 1 OF 2

THIS ADDENDUM IS ISSUED TO MODIFY, CLARIFY, AND ADD TO THE PREVIOUSLY ISSUED CONTRACT DOCUMENTS.

PLEASE ATTACH THIS ADDENDUM THERETO AND INCLUDE COST CHANGES IN THE FINAL BID. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE SPACE ON THE PROPOSAL FORM.

DRAWINGS OR SKETCHES ISSUED:

SPECIFICATIONS ISSUED:

DRAWING CORRECTIONS, REVISIONS, MODIFICATIONS, OR CLARIFICATIONS:

Drawing C-1 – Overall Site Plan (Not Reissued)

Pavement Striping Note

Add NOTE: STRIPING FOR EAST AND WEST PARKING LOTS TO BE INCLUDED IN BASE BID

Drawing C-2 – Plan Details (Not Reissued)

Add the following note to sheet below Surface Legend

CONCRETE FINISH NOTE:

ALL NEW CONCRETE TO RECEIVE A MEDIUM-TO-FINE-TEXTURED BROOM FINISH AS DESCRIBED IN THE SPECIFICATIONS.

Detail G - Island Removal & Replacement Plan (Alternate No.4)

Add note to concrete on south side of island to be remain and note "REMOVE AND REPLACE JOINT SEALANT IN FLAGS THAT ARE TO BE SAWCUT TO REMOVE ISLAND"

Add note "NOTE: RELOCATE SIGNAGE TO OTHER SIDE OF GREENWOOD AVENUE - CONTRACTOR TO COORDINATE FINAL LOCATION OF SIGNAGE WITH OWNER"

SPECIFICATION CORRECTIONS, REVISIONS, MODIFICATIONS, OR CLARIFICATIONS:

Complete Bid Form (Revised and Reissued)
With HUD Non-Collusive Affidavit Prime Bidder Revised Document (Re-Issued)

SECTION 321313 – CONCRETE PAVING

2.6 CONCRETE MIXTURES

E. Concrete Mixtures: Normal-weight concrete

Revise 1. Compressive Strength (28 Days): 3500 psi (24.1 MPa) to now read
Compressive Strength (28 Days): 4000 psi (27.58 MPa)